LISTING SERVICE

LISTING No.	7150-0694:107	Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Models MS-1, -1P, -2, -2H, -2L, and -2P with or without suffix -D; Models   MS-6, -6D, 6DP*, -6PT*, and -6T* non coded, manual pull stations. Models MS-1P, -1P-D, -2L and -2L-D employ pull handle key lock (A key is required to unlock before these pull stations can be operated). Models with suffix -2H have a "Halon Release" label on the front panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual pull stations for use with separately listed compatible fire alarm control units. Models with key lock shall have approval from authority having jurisdiction prior to installation.

Rev. 06-11-2002

Date Issued: **JUNE 21, 2003**   *Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager